

# Fair Lawn Public Schools

**Joanne Wilson**  
Business Administrator/Board Secretary

37-01 Fair Lawn Avenue  
Fair Lawn, New Jersey 07410  
Tele: (201)794-5500  
Fax: (201)703-4630

E-mail: [jwilson@fairlawnschools.org](mailto:jwilson@fairlawnschools.org)

April 7, 2017

Dear Parents and Staff:

In the Spring of 2016 the school district contracted with ERM, an environmental company, to perform sample testing of the lead levels in the drinking water. In July 2016 the State of New Jersey passed additional requirements to N.J.A.C. 6A:26 which now includes mandatory testing in public school districts as well as a Quality Assurance Project Plan (QAPP) and water sample plans. The school district has until July 2017 to comply and the prior testing will not meet the new regulations.

Mandatory testing at elementary schools and middle schools took place during February Break 2017. Testing results we have received to date can be found on each school website. Bergen Avenue building and Edison School test results are included on the District website. Also included is a link to information from the State of New Jersey regarding health effects with lead and information on school water sources.


Remedial action was taken on all sources that exceeded the acceptable level of lead which is fifteen (15) parts per billion (ppb). The sources were taken out of service. Filters will be installed and a second round of testing will be performed over April Break 2017.

The High School was sampled on March 12, and April 2, 2017. Results will be posted on the district and school website as they are received and interpreted.

More information on drinking water facts can be found at:

[http://www.state.nj.us/health/ceohs/documents/dwf\\_lead\\_schools.pdf](http://www.state.nj.us/health/ceohs/documents/dwf_lead_schools.pdf)

Sincerely,



Joanne Wilson  
Business Administrator/Board Secretary

cc: NJ Department of Education  
NJ Department of Education – Bergen County  
Board of Education  
ERM



Environmental  
& Remediation &  
Management, Inc.

20-10 Maple Ave, Bldg. 35E  
Fair Lawn, NJ 07410  
Tele: (973) 949-3525  
Fax: (973) 949-3526  
Email: ermrnj@aol.com

CLIENT: Fair Lawn Board of Education Pr. No.: 1044-366

PROJECT: District Wide Lead (Pb) in water sampling (Radburn Elementary School)

FIELD TECHNICIANS: Anastasia Leverence

REPORT DATE: April 5, 2017

Environmental Remediation & Management, Inc. was contacted by The Fair Lawn Board of Education to conduct a District wide Lead (Pb) in water sampling.

Anastasia Leverence, an environmental field technicians with ER&M, arrived at the project site at approximately 8:30 am on February 21, 2017 and proceeded to collect water samples from designated drinking fountains and cooking sinks.

Samples were analyzed at EMSL Analytical, Inc. in Cinnaminson, New Jersey (NJDEP#03036), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). Analytical method was by Lead in Water by inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

Ten samples within the Radburn Elementary School came back at or above the recommended 'action level' as established by The United States Environmental Protection Agency (USEPA) of 15 parts per billion (ppb). All collected samples are First Draw Samples – first 250 ml of cold water collected from the drinking water outlet. The water in the school facility must remain motionless in the plumbing for a minimum 8 hours but no more than 48 hours.

### **RADBURN ELEMENTARY SCHOOL LEAD (PB) IN WATER RESULTS OF CONCERN**

Sample No.	Location	Results
FLREBDW3	Hall by Room 17	20.6 ppb
FLREBDW4	Hall by Room 14	20.4 ppb
FLREBDW5	Room 14	36.6 ppb
FLREBDW6	Room 16	46.6 ppb
FLREBDW7	Hall across Room 16	97.4 ppb
FLREBDW8	Hall across Room 16	17.6 ppb
FLRECDW3	Room 23	20.8 ppb
FLRECDW4	Room 24	24.9 ppb
FLRECDW6	Room 26	27.8 ppb

FLRECDW7	Room 27	17.6 ppb
FLREADWS	Hall by Boiler Room	28.9 ppb

\*Highlighted results are at or exceed the USEPA allowable limit of 15 Parts Per Billion (ppb).

At this moment we recommend the some or all of the following steps be taken

- Permanent closure of certain water taps.
- Removal and replacement with non-lead containing fixtures.
- Contact the water utility to obtain information about their corrosion control procedures and how it might affect the Districts control plans.
- Development of a Flushing Program for those taps high in lead and turbidity. This may include automatic flushing systems.
- Installation of filtration systems (including post installation performance monitoring)

If you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision / ER&M looks forward to providing your home with the service and attention to detail you have come to expect from us.

Sincerely,



Guillermo M. Morales  
EnviroVision Consultants, Inc.  
Environmental Remediation & Management, Inc.



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 949-4571 Email: EnvChem@red.com

Attn: **Willie Morales**  
**Environmental Remediation & Management**  
**20-10 Maple Ave**  
**Building 35E**  
**Fair Lawn, NJ 07410**  
Phone: (973) 949-3525  
Fax: (973) 949-3526

4/6/2017

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 2/23/2017. The results are tabulated on the attached data pages for the following client designated project:

**Fairlawn Radburn**

The reference number for these samples is EMSL Order #011701396. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry  
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 66-00367, CA ELAP 1877

Report amended 04/06/2017 15:26:05 Replaces Initial report from 03/01/2017 13:48:16

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com>      [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011701396  
 CustomerID: ENV176  
 CustomerPO:  
 ProjectID:

Attn: **Willie Morales**  
**Environmental Remediation & Management**  
**20-10 Maple Ave**  
**Building 35E**  
**Fair Lawn, NJ 07410**

Phone: (973) 949-3525  
 Fax: (973) 949-3526  
 Received: 02/23/17 10:00 AM

Project: Fairlawn Radburn

**Analytical Results**

Client Sample Description		FLREFB	Collected:	2/21/2017	Lab ID:	0001		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/27/2017	AE	2/27/2017	EG
Client Sample Description		FLREADW1	Collected:	2/21/2017	Lab ID:	0002		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREADW2	Collected:	2/21/2017	Lab ID:	0003		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREADW3	Collected:	2/21/2017	Lab ID:	0004		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.93	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREAIM1	Collected:	2/21/2017	Lab ID:	0005		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREAS1	Collected:	2/21/2017	Lab ID:	0006		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREADW4	Collected:	2/21/2017	Lab ID:	0007		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.60	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREADWS	Collected:	2/21/2017	Lab ID:	0008		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry@emsl.com](mailto:EnvChemistry@emsl.com)

EMSL Order: 011701396  
 CustomerID: ENVI76  
 CustomerPO:  
 ProjectID:

Attn: **Willie Morales**  
**Environmental Remediation & Management**  
**20-10 Maple Ave**  
**Building 35E**  
**Fair Lawn, NJ 07410**

Phone: (973) 949-3525  
 Fax: (973) 949-3526  
 Received: 02/23/17 10:00 AM

Project: Fairlawn Radburn

**Analytical Results**

Client Sample Description		FLREADWS	Collected:	2/21/2017	Lab ID:	0008		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	28.9	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREAS2	Collected:	2/21/2017	Lab ID:	0009		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.5	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREBDW1	Collected:	2/21/2017	Lab ID:	0010		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.76	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREBDW2	Collected:	2/21/2017	Lab ID:	0011		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.48	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREBDW3	Collected:	2/21/2017	Lab ID:	0012		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	20.6	1.00	µg/L	2/27/2017	AE	2/27/2017	EG
Client Sample Description		FLREBDW4	Collected:	2/21/2017	Lab ID:	0013		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	20.4	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREBDW5	Collected:	2/21/2017	Lab ID:	0014		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	36.6	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREBDW6	Collected:	2/21/2017	Lab ID:	0015		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com>    [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011701396  
 CustomerID: ENV176  
 CustomerPO:  
 ProjectID:

Attn: **Willie Morales**  
**Environmental Remediation & Management**  
**20-10 Maple Ave**  
**Building 35E**  
**Fair Lawn, NJ 07410**

Phone: (973) 949-3525  
 Fax: (973) 949-3526  
 Received: 02/23/17 10:00 AM

Project: Fairlawn Radburn

**Analytical Results**

Client Sample Description		FLREBDW6	Collected:	2/21/2017	Lab ID:	0015		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	46.6	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREBDW7	Collected:	2/21/2017	Lab ID:	0016		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	97.4	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREBDW8	Collected:	2/21/2017	Lab ID:	0017		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	17.6	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREBS1	Collected:	2/21/2017	Lab ID:	0018		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREBS2	Collected:	2/21/2017	Lab ID:	0019		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.55	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREBDW9	Collected:	2/21/2017	Lab ID:	0020		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.57	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREBS3	Collected:	2/21/2017	Lab ID:	0021		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.71	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREBS4	Collected:	2/21/2017	Lab ID:	0022		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011701396  
 CustomerID: ENVI76  
 CustomerPO:  
 ProjectID:

Attn: **Willie Morales** Phone: (973) 949-3525  
**Environmental Remediation & Management** Fax: (973) 949-3526  
**20-10 Maple Ave** Received: 02/23/17 10:00 AM  
**Building 35E**  
**Fair Lawn, NJ 07410**  
 Project: Fairlawn Radburn

**Analytical Results**

Client Sample Description		FLREBS4	Collected:	2/21/2017	Lab ID:	0022		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.13	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLREBDW10	Collected:	2/21/2017	Lab ID:	0023		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.28	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLRECDW1	Collected:	2/21/2017	Lab ID:	0024		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.45	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLRECDW2	Collected:	2/21/2017	Lab ID:	0025		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.8	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLRECDW3	Collected:	2/21/2017	Lab ID:	0026		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	20.8	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLRECDW4	Collected:	2/21/2017	Lab ID:	0027		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	24.9	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLRECDW5	Collected:	2/21/2017	Lab ID:	0028		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.5	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLRECDW6	Collected:	2/21/2017	Lab ID:	0029		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011701396  
 CustomerID: ENVI76  
 CustomerPO:  
 ProjectID:

Attn: **Willie Morales**  
**Environmental Remediation & Management**  
**20-10 Maple Ave**  
**Building 35E**  
**Fair Lawn, NJ 07410**

Phone: (973) 949-3525  
 Fax: (973) 949-3526  
 Received: 02/23/17 10:00 AM

Project: Fairlawn Radburn

**Analytical Results**

Client Sample Description		FLRECDW6	Collected:	2/21/2017	Lab ID:	0029		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	27.8	1.00	µg/L	2/24/2017	AE	2/27/2017	EG
Client Sample Description		FLRECDW7	Collected:	2/21/2017	Lab ID:	0030		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	17.6	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLRECDW8	Collected:	2/21/2017	Lab ID:	0031		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.18	1.00	µg/L	2/23/2017	AE	2/24/2017	EG
Client Sample Description		FLRECDW9	Collected:	2/21/2017	Lab ID:	0032		
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.78	1.00	µg/L	2/23/2017	AE	2/24/2017	EG

**Definitions:**

ND - indicates that the analyte was not detected at the reporting limit  
 RL - Reporting Limit (Analytical)

### Lead (Pb) Chain of Custody EMSL Order ID (Lab Use Only):

011701396

PHONE:  
FAX:

Company: <b>ER+M, INC</b>		EMSL-Bill to: <input type="checkbox"/> Different <input checked="" type="checkbox"/> Same <small>If Bill to is Different note instructions in Comments**</small>		
Street: <b>#10 Maple Ave</b>		<i>Third Party Billing requires written authorization from third party</i>		
City: <b>Fair Lawn</b>	State/Province: <b>NJ</b>	Zip/Postal Code:	Country:	
Report To (Name): <b>Willie Morales</b>		Telephone #:		
Email Address: <b>CRINT@GOI.COM</b>		Fax #:	Purchase Order:	
Project Name/Number: <b>FAIRLAWN RADBURN</b>		Please Provide Results: <input type="checkbox"/> FAX <input type="checkbox"/> E-mail <input type="checkbox"/> Mail		
U.S. State Samples Taken: <b>NJ</b>		CT Samples: <input type="checkbox"/> Commercial/Taxable <input type="checkbox"/> Residential/Tax Exempt		
<b>Turnaround Time (TAT) Options* - Please Check</b>				
<input type="checkbox"/> 3 Hour	<input type="checkbox"/> 6 Hour	<input type="checkbox"/> 24 Hour	<input type="checkbox"/> 48 Hour <input type="checkbox"/> 72 Hour <input type="checkbox"/> 96 Hour <input type="checkbox"/> 1 Week <input checked="" type="checkbox"/> 2 Week	
<small>*Analysis completed in accordance with EMSL's Terms and Conditions located in the Price Guide</small>				
Matrix	Method	Instrument	Reporting Limit	Check
Chips <input type="checkbox"/> % by wt. <input type="checkbox"/> mg/cm <sup>2</sup> <input type="checkbox"/> ppm	SW846-7000B	Flame Atomic Absorption	0.01%	<input type="checkbox"/>
Air	NIOSH 7082	Flame Atomic Absorption	4 µg/filter	<input type="checkbox"/>
	NIOSH 7105	Graphite Furnace AA	0.03 µg/filter	<input type="checkbox"/>
	NIOSH 7300 modified	ICP-AES/ICP-MS	0.5 µg/filter	<input type="checkbox"/>
Wipe* <small>ASTM <input type="checkbox"/> non ASTM <input type="checkbox"/> *If no box is checked, non-ASTM Wipe is assumed</small>	SW846-7000B	Flame Atomic Absorption	10 µg/wipe	<input type="checkbox"/>
	SW846-6010B or C	ICP-AES	1.0 µg/wipe	<input type="checkbox"/>
	SW846-7000B/7010	Graphite Furnace AA	0.075 µg/wipe	<input type="checkbox"/>
TCLP	SW846-1311/7000B/SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW846-1131/SW846-6010B or C	ICP-AES	0.1 mg/L (ppm)	<input type="checkbox"/>
Soil	SW846-7000B	Flame Atomic Absorption	40 mg/kg (ppm)	<input type="checkbox"/>
	SW846-7010	Graphite Furnace AA	0.3 mg/kg (ppm)	<input type="checkbox"/>
	SW846-6010B or C	ICP-AES	2 mg/kg (ppm)	<input type="checkbox"/>
Wastewater <small>Unpreserved <input type="checkbox"/> Preserved with HNO<sub>3</sub> pH &lt; 2 <input type="checkbox"/></small>	SM3111B/SW846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	EPA 200.9	Graphite Furnace AA	0.003 mg/L (ppm)	<input type="checkbox"/>
	EPA 200.7	ICP-AES	0.020 mg/L (ppm)	<input type="checkbox"/>
Drinking Water <small>Unpreserved <input type="checkbox"/> Preserved with HNO<sub>3</sub> pH &lt; 2 <input checked="" type="checkbox"/></small>	EPA 200.9	Graphite Furnace AA	0.003 mg/L (ppm)	<input type="checkbox"/>
	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	<input checked="" type="checkbox"/>
TSP/SPM Filter	40 CFR Part 60	ICP-AES	12 µg/filter	<input type="checkbox"/>
	40 CFR Part 50	Graphite Furnace AA	3.6 µg/filter	<input type="checkbox"/>
Name of Sampler: <b>Anastasia Levenska</b>		Signature of Sampler: <i>[Signature]</i>		
Sample #	Location	Volume/Area	Date/Time Sampled	
	<i>see attached</i>			
Client Sample #'s		Total # of Samples:	<b>32</b>	
Relinquished (Client): <i>[Signature]</i>	Date: <b>2-21</b>	Time: <b>3:00</b>		
Received (Lab): <i>[Signature]</i>	Date: <b>2/22/17</b>	Time: <b>7 pm</b>		
Comments:				

*Received W. M. Russo  
2/23/2017  
10:00 AM  
21°*

**LEAD (Pb) CHAIN OF CUSTODY**  
**EMSL ORDER ID (Lab Use Only):**

011701396

PHONE:  
FAX:

*Additional Pages of the Chain of Custody are only necessary if needed for additional sample information*

Sample #	Location	Volume/Area	Date/Time Sampled	
FLREFB	Field BLANK	250 ml	2-21 12 <sup>30</sup>	1
FLREADW1	Hall by Kitchen	250 ml	2-21 12 <sup>33</sup>	2
FLREADW2	Hall by Kitchen	250 ml	2-21 12 <sup>36</sup>	3
FLREADW3	Hall by B3	250 ml	2-21 12:40	4
FLREAIM4	Kitchen	250 ml	2-21 12:43	5
FLREAS1	Kitchen	250 ml	2-21 12:43	6
FLREADW4	Room B1	250 ml	2-21 12:49	7
FLREADW5	Hall by Boiler Room	250 ml.	2-21 12:53	8
FLREAS2	Media Center Kitchenette	250 ml	2-21 12:56	9
FLREBDW1	Room 11	250 ml	2-21 1:04	10
FLREBDW2	Hall by Room 11	250 ml	2-21 1:07	11
FLREBDW3	Room 12	250 ml	2-21 1:11	12
FLREBDW4	Hall by Room 14	250 ml	2-21 1:15	13
FLREBDW5	Room 14	250 ml	2-21 1:18	14
FLREBDW6	Room 16	250 ml	2-21 1:22	15
FLREBDW7	Hall across Room 16	250 ml	2-21 1:25	16
FLREBDW8	Hall across Room 16	250 ml	2-21 1:28	17
FLREBS1	Faculty Room	250 ml	2-21 1:31	18
<b>Comments/Special Instructions:</b>				

**LEAD (Pb) CHAIN OF CUSTODY**

EMSL ORDER ID (Lab Use Only):

011701396

PHONE:

FAX:

*Additional Pages of the Chain of Custody are only necessary if needed for additional sample information*

Sample #	Location	Volume/Area	Date/Time Sampled	
FLREBS2	Room A-2	250 ml	2-21 1:33	19
FLREBDW9	Hall by Nurse	250 ml	2-21 1:38	20
FLREBS3	Nurse	250 ml	2-21 1:42	21
FLREBS4	Nurse	250 ml	2-21 1:44	22
FLREBDW10	Room A-1	250 ml	2-21 1:48	23
FLRECDW1	Hall by Room 20	250 ml	2-21 1:55	24
FLRECDW2	Room 21	250 ml	2-21 1:58	25
FLRECDW3	Room 23	250 ml	2-21 2:03	26
FLRECDW4	Room 24	250 ml	2-21 2:07	27
FLRECDW5	Room 25	250 ml	2-21 2:11	28
FLRECDW6	Room 26	250 ml	2-21 2:15	29
FLRECDW7	Room 27	250 ml	2-21 2:19	30
FLRECDW8	Hall by Room 27	250 ml	2-21 2:23	31
FLRECDW9	Hall by Room 27	250 ml	2-21 2:27	32
<b>Comments/Special Instructions:</b>				



## EMSL Analytical, Inc. Sample Transfer Form

<b>Receiving Lab:</b>	EMSL- MANHATTAN	<b>Phone Number:</b>	(212) 290-0051	
		<b>Fax Number:</b>	(212) 290-0058	
<b>Relinquished to:</b>	EMSL- CINNAMINSON	<b>Phone Number:</b>	(800) 220-3675	
		<b>Fax Number:</b>	(856) 786-5974	
<b>Does new lab hold equivalent or additional accreditation? *</b>			<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
<b>EMSL Customer ID # (if known):</b>				
<b>Client Name:</b> ER+M INC				
<b>Client Project:</b> FAIRLAWN RADBURN				
<b>Tests to be Performed:</b> LEAD IN WATER				
<b>Date Received:</b> 2/22/17				
<b>Date Relinquished:</b> 2/22/17				
<b>Date Due:</b> TAT 2 WEEK				
<b>Special Instructions:</b> (e.g. Work Order # , required qualifications, project specific procedures/modifications)				
<b>Relinquished by (Signature):</b>		<b>Date:</b>	<b>Received by (Signature):</b>	
		2/22/17		
<b>Relinquished by (Signature):</b>		<b>Date:</b>	<b>Received by (Signature):</b>	
		02-22-17	AM COURIER	
<b>Customer Agreement-</b> Please sign form and send to the receiving laboratory. By signing below, you agree to permit the above named receiving lab to transfer samples to a separate EMSL lab with equivalent qualifications* for analysis. The final report will be issued from the analyzing laboratory. Ensure any requirements are listed in special instructions.				
<b>Name (please print):</b>		<b>Signature:</b>	<b>Agent of:</b>	<b>Date:</b>
<i>If this is a recurring project or sample type that may require samples to be relinquished on a regular basis, a Standing Agreement form must be completed.</i>				

\* Receiving and analyzing labs shall be aware of required qualifications of project prior to transfer of samples.  
 Note: If customer has been notified and approved this transfer verbally or by e-mail, the receiving lab must sign for the customer above. EMSL employee filling out form on behalf of customer shall print name of person to whom they spoke, date agreement was received, and then sign under Signature.

State of New Jersey  
Department of Environmental Protection

**EMSL Analytical Inc**

Laboratory Certification ID # 03036

*is hereby approved as a*

*Nationally Accredited Environmental Laboratory  
to perform the analyses as indicated on the Annual Certified Parameter List  
which must accompany this certificate to be valid*

*having duly met the requirements of the  
Regulations Governing the Certification of  
Laboratories and Environmental Measurements N.J.A.C. 7:18 et. seq.*

*having been found compliant with the 2009 TNI Standard approved by the  
The NELAC Institute*

**Expires June 30, 2017**



*Michael J. Potts*  
Michael J. Potts  
Interim Manager



**NOTE: is a NELAP Recognized Accreditation Body**

This certificate is to be permanently displayed at the laboratory with the annual report of performance for a violation on the previous tests in the public. Expiration date subject to verify the Department's current website for updates to the State of NJ NELAP.